

SITE PLAN 1/16" = 1'- 0"



2 VICINITY MAP

DSA **810**

LOCAL FIRE AUTHORITY REVIEW

To facilitate the Division of the State Architect's (DSA) approval of the Fire/Life Safety portion of a project, DSA requires Local Fire Authority (LFA) review of certain elements as identified in this form. Use of this form is mandatory for projects that add square footage to a campus or if any item on this form is relevant to the project. For additional information, see DSA 810 Instructions and DSA Policy 09-01.

PROJECT INFORMATION

School District/Owner: San Diego Unified School District
Project Name/School: Ocean Discovery Institute - Solar Trees
Project Address: 4255 Thorn Street, San Diego 92105

LOCAL FIRE AUTHORITY (LFA)

LFA Agency Name: San Diego Fire Rescue
LFA Reviewer Name: B. Sylvester Title: Deputy Fire Marshal
Email: bsylvester@sandiego.gov Telephone Number: 619 446 - 5449

I have reviewed and responded to the applicable items for this project as listed below.
Note: *Only sign this form when it is imprinted on the fire plan. A loose form is not acceptable to DSA.*
LFA Reviewer's Signature: Date: 2-16-17

Review Key: **"Y"** = Complies with LFA requirements **"N"** = Not approved (complete Section 8)
"NA" = Not applicable to the project **"NR"** = LFA elects not to review

	Description	Y	N	NA	NR
1	Where an elevator does not meet medical emergency service cab size, per the California Building Code (CBC), use of stairways for emergency rescue and patient transport is acceptable.			NA	
2	Access roads, fire lane markings, pavers and gate entrances are in accordance with Title 19, California Code of Regulations and the California Fire Code, Chapter 5.	Y			
3	Fire hydrant location and distribution complies with the California Fire Code (or see # 4).	Y			
4	Fire hydrant location and distribution complies with NFPA 1142, "Alternate Means." If "NR" is checked, DSA can only approve on-site water storage as an alternate. The signature of the school district official is required to acknowledge the use of alternate means. **Signature of School District Official:** _____ **Date:** _____ **Print the School District Official's Name:** _____				NR
5	The location(s) of the proposed post indicator valve and fire department connection meet the requirements of this jurisdiction.			NA	
6	The location(s) of the detector check valve assembly meet the requirements of this jurisdiction.			NA	
7	Is the project located in a hazard severity zone area? (CBC, Chapter 7A, Section 701A.) ☐ Yes ☒ No Check type if "Yes": ☐ Moderate ☐ High ☐ Very High ☐ WIFA (If one of these boxes is checked, the project design must meet the requirements of Chapter 7A.)			NA	
8	COMMENTS (note deficiencies):				

DSA 810 (rev 05-12-14) DEPARTMENT OF GENERAL SERVICES Page 1 of 1
DIVISION OF THE STATE ARCHITECT STATE OF CALIFORNIA

REVIEWED BY
EXECUTIVE DIRECTOR FPC — DATE
DIRECTOR FPC — DATE
DIRECTOR PROJECT MANAGEMENT FPC — DATE
DISTRICT ARCHITECT — DATE

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
AC_____ FLS_____ SS_____
DATE_____
DSA

CONSULTANT

ARCHITECT/CONSULTANT
LICENSED ARCHITECT · STATE OF CALIFORNIA · ROB WELLINGTON QUIGLEY · No. C 36917 · REN 2/28/19

SAN DIEGO UNIFIED SCHOOL DISTRICT

PREPARED FOR THE
BOARD OF EDUCATION
SAN DIEGO UNIFIED SCHOOL DISTRICT
SAN DIEGO, CALIFORNIA

PREPARED BY THE
FACILITIES PLANNING AND CONSTRUCTION
PROJECT MANAGEMENT DEPARTMENT

OCEAN DISCOVERY INSTITUTE
48.30 kWDC PHOTOVOLTAIC PROJECT
4255 THORN STREET
SAN DIEGO, CALIFORNIA
CONSTRUCTION DOCUMENTS

PROJECT NO.
R.S. - A.P. -
FILE NAME -
DATE **3/22/17** DRAWN -
CHECKED -
REVISIONS - - - - -
SHEET NO. **G-006**
OF - SHEETS